



***Tussing Road Water
Treatment System
Drinking Water
Consumer
Confidence Report
For 2008***



The Tussing Road Water Treatment System has prepared the following report to provide information to you, the consumer, on the quality of our drinking water. Included within this report is general health information, water quality test results, how to participate in decisions concerning your drinking water and water system contacts.

The Tussing Road, Water Treatment System receives its drinking water from two distinct underground aquifers located within the County-owned Violet Township wellfield adjacent to the treatment facility. The groundwater supply is delivered to the treatment facility by nine wells located throughout the wellfield.

The Tussing Road, Water System also has emergency connections with the City of Columbus, City of Pickerington, and Southwest Licking County Water and Sewer District. This report does not contain information on the water quality of these other systems. A copy of their consumer confidence report can be obtained by contacting them.

The shallow aquifer that supplies drinking water to Fairfield County's Violet wellfield has a moderate susceptibility to contamination, due to the moderately sensitive nature of the aquifer in which the drinking water wells are located and the existing potential contaminant sources identified. This does not mean that the shallow aquifer will become contaminated, only that conditions are such that the groundwater could be impacted by potential contaminant sources. The deep aquifer that supplies drinking water to Fairfield County's Violet wellfield has a low susceptibility to contamination, due to the low sensitivity of the aquifer in which the drinking water wells are located and the existing potential contaminate sources identified. This does not mean that the deep aquifer cannot be contaminated, only that the likelihood of contamination is relatively low.

Future contamination of the shallow and deep aquifers can be avoided by implementing protective measures.

Fairfield County has implemented, and will continue to implement, protective measures to prevent contamination of the drinking water sources. More information is available by contacting Roger A. Donnell, Chief Water Operator, at (614) 864-3370 or Ohio EPA at (614) 644-2752.

The sources of drinking water both tap water and bottled water include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring

minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include: (A) Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife; (B) Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming; (C) Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses; (D) Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems; (E) radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, USEPA prescribes regulations, which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly

and infants can be particularly at risk from infection. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Definitions of some terms contained within this report
Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Contaminant level (MCL): The highest level of contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Parts per Million (ppm) or Milligrams per Liter (mg/L) are units of measure for concentration of a contaminant. A part per million corresponds to one second in a little over 11.5 days.

Parts per Billion (ppb) or Micrograms per Liter (ug/L) are units of measure for concentration of a contaminant. A part per billion corresponds to one second in 31.7 years.

The "<" symbol: A symbol which means less than. A result of <5 means that the lowest level that could be detected was 5 and the contaminant in that sample was not detected.

The EPA requires regular sampling to ensure drinking water safety. The Tussing Road, Water System conducted sampling for bacteria; radioactive, inorganic, and organic chemical contaminants; haloacetic acids; total trihalomethanes; nitrate; fluoride; and sodium during 2008. Of the contaminant sampling conducted, most were not detected in the Tussing Road, Water System water supply. The Ohio EPA requires us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though accurate, are more than one year old.

Listed are the results from the sampling conducted in 2008 on the Tussing Road, Water System as required by the EPA.

REGULATED HEALTH RELATED STANDARDS: This table provides health related information about the quality of the water supplied to the water system in 2008 by the Utilities Department. This information is intended to assist our customers in making informed decisions regarding the consumption, protection and conservation of the water supply.

INORGANIC CONTAMINANTS	MCL G	MCL	LEVEL FOUND	RANGE OF DETENTION	SAMPLE YEAR	ARE WE IN COMPLIANCE	TYPICAL SOURCE OF CONTAMINANTS
			TUSSING ROAD WATER				
NITRATE (mg/l)	10	10	0.38 mg/l	N/A	2008	YES	RUNOFF FROM FERTILIZER USE, LEACHING FROM SEPTIC TANKS, SEWAGE, EROSION OF NATURAL DEPOSITS
FLUORIDE (mg/l)	4	4	1.01 mg/l	0.9-1.1 mg/l	2008	YES	WATER ADDITIVE WHICH PROMOTES STRONG TEETH
ARSENIC (ug/l)	0	10	4.2 ug/l	N/A	2008	YES	EROSION OF NATURAL DEPOSITS
BARIUM (ug/l)	2000	2000	30.4 ug/l	N/A	2008	YES	EROSION OF NATURAL DEPOSITS; DISCHARGE OF DRILLING WASTES; DISCHARGE FROM METAL REFINERIES
COPPER LEVEL IN DRINKING WATER MAY BE ELEVATED WHEN COPPER SERVICE LINES ARE USED IN A HOUSE OR BUSINESS. ADDITIONALLY, IF YOUR RESIDENCE HAS AN IMPROPER ELECTRICAL GROUND, COPPER LEVELS IN THE DRINKING WATER MAY INCREASE. FOR MORE INFORMATION ON COPPER IN DRINKING WATER, PLEASE CONTACT THE WATER DIVISION.							
RADIOACTIVE CONTAMINANTS							
RADIUM 228 (pCi/l)	NA	5	<1.0	<1.0	2008	YES	EROSION OF NATURAL DEPOSITS; DISCHARGE OF DRILLING WASTES; DISCHARGE FROM METAL REFINERIES
ORGANIC CONTAMINANTS - Disinfection By-Products							
BROMODICHLOROMETHANE (ug/l)	NA	NA	9.30	9.30	2008	YES	BYPRODUCT OF DRINKING WATER CHLORINATION
BROMOFORM (ug/l)	NA	NA	1.60	1.60	2008	YES	BYPRODUCT OF DRINKING WATER CHLORINATION
CHLOROFORM (ug/l)	NA	NA	7.70	7.70	2008	YES	BYPRODUCT OF DRINKING WATER CHLORINATION
DIBROMOCHLOROMETHANE (ug/l)	NA	NA	7.70	7.70	2008	YES	BYPRODUCT OF DRINKING WATER CHLORINATION
HALOACETIC ACIDS 5	NA	60	6.2 ug/l	6.2 ug/l	2008	YES	BYPRODUCT OF DRINKING WATER CHLORINATION
TOTAL TRIHALOMETHANES	NA	80	26.30 ug/l	26.30 ug/l	2008	YES	BYPRODUCT OF DRINKING WATER CHLORINATION
NON-REGULATED HEALTH STANDARDS: Non-Mandatory Water Quality Standards					UNIT	SECONDARY LEVELS	TUSSING ROAD WATER
IRON	IRON IS NOT A HEALTH RELATED STANDARD BUT IS AESTHETICALLY UNPLEASANT FROM ITS YELLOWISH TO BROWNISH COLOR AND STALE TASTE				mg/l	0.30	0.08-0.09 mg/l
MANGANESE	MANGANESE IS NOT A HEALTH RELATED STANDARD BUT IS AESTHETICALLY UNPLEASANT DUE TO ITS ABILITY TO CAUSE BLACK STAINS				mg/l	0.05	0.03-0.04 mg/l
HARDNESS	PRIMARILY MADE UP OF CALCIUM AND MAGNESIUM SALTS. SOFT WATER CREATES SUDS EASIER. WATER TOO SOFT CAN BE CORROSIVE. THE HARDER THE WATER, THE MORE RESIDUAL DEPOSITS. OEPA RECOMMENDS HARDNESS IN THE RANGE OF 120-160 mg/l				mg/l	NA	92.5-127 mg/l
PHOSPHATE	ADDED TO HELP PREVENT LEACHING OF COPPER OR LEAD INTO THE WATER AND SEQUESTER ANY RESIDUAL IRON OR MANGANESE				mg/l	NA	0.49-0.71 mg/l
SODIUM	INFORMATION FOR THOSE WHO MAY BE ON A SODIUM RESTRICTED DIET				mg/l	NA	135-196 mg/l
CHLORINE	ADDED TO DISINFECT THE WATER				mg/l	NA	1.15-1.26 mg/l

Public participation and comment are encouraged at regular meetings of the Board of Fairfield County Commissioners, which meets weekly on Tuesdays at 10:00 am in the Commissioners Hearing Room, Fairfield County Courthouse, 210 E Main Street, Lancaster, OH.

Contact Information

Fairfield County Utilities
 Billing & Administration
 210 E. Main Street, Room 302
 Lancaster, Ohio 43130
 740-687-7154
 614-833-0884
 www.co.fairfield.oh.us/util/

Tony Vogel, P.E.
 Director of Utilities
 tvogel@co.fairfield.oh.us
 Donald R. Sherman, P.E.
 Deputy Director of Utilities
 dsherman@co.fairfield.oh.us
 Pam Shaloo
 Office Manager
 pshaloo@co.fairfield.oh.us

Field Operations
 11050 Tussing Road
 Pickerington, OH 43147
 614-864-3370

Tom Bouts
 Superintendent of Utilities
 tbouts@co.fairfield.oh.us
 Roger A Donnell
 Chief Water Operator
 rdonnell@co.fairfield.oh.us

If you have any questions regarding your drinking water, please contact Roger Donnell, Chief Water Operator, to discuss your concerns.

Fairfield County Utilities
 Certified Drinking Water Operators

- Roger Donnell, Class I Rick Krueger, Class II
- Berry McCain, Class III Thomas Bouts, Class I
- Brandon Fox, Class III
- Ted Schmelzer, Class III