

BACKFLOW PREVENTION ASSEMBLY TEST REPORT

FAILED, ILLEGIBLE OR INCOMPLETE REPORTS WILL NOT BE ACCEPTED

Mail: 6670 Lockville Rd., Carroll, OH 43112 Fax: (614) 322-5203, (740) 652-7129 Email: FC-utilities@fairfieldcountyohio.gov

Customer and Property Information – Please Print

PROPERTY A	ADDRESS:_									Zip			
BUSINESS NA	AME												
CONTACT PERSON:				PHONE#					_FAX#				
					Device Inform	ation — I	Please I	<u>Print</u>					
NEW INSTAL	LATION	EXISTING	□ or F	REPL	ACEMENT □ OLD	ASSEM	BLY SI	ERIAL N	UMBEF	R:			
TYPE OF ASS	SEMBLY (CI	IRCLE ONE)	A	AIR G	APRP DC	PVB	OTI	HER (SP	ECIFY)				
MAKE OF ASSEMBLY: M				ODEL:SIZE:S					ERIAL NO.:				
What hazard i	s being isolat	ted? (i.e. boiler	irrigatio	n, cor	nplete building):								
Describe locati	ion of assemb	oly:											
Double Check Assembly					Reduced Pressure Assembly					Pressure Vacuum Breaker			
Initial Test	Outlet Valve	Pass	Fail		1st Check Valve		_psid	Pass Fail		Air Inlet Valve	psig	Pass Fail	
	1st Check Valve	psid	Pass Fail		Relief Valve Opening Point		_psid	Pass Fail		Check Valve	psig	Pass Fail	
	2 nd Check Valve	psid	Pass Fail		2 nd Check Valve		_psid	Pass Fail					
					Outlet Valve	Pass		Fail					
Repairs & Materials Used													
Re-Test After Repairs	Outlet Valve	——psid	Pass Fail		1st Check Valve		_psid	Pass Fail		Air Inlet Valve	——psig	Pass Fail	
	1st Check Valve	psid	Pass Fail		Relief Valve Opening Point		_psid	Pass Fail		Check Valve	psig	Pass Fail	
	2 nd Check Valve	psid	Pass Fail		2 nd Check Valve		_psid	Pass Fail AIR GAP INS		l Air Gap Sep	Gap Separation		
	Valve				Outlet Valve	Pass		Fail		Provided? Yes \(\square\) No			
Assembly	PASSED	() F .	AILED)(rements? YES [) * NOTE: AL	– L REPAI	RS MU	ST BE C	OMPLE	ETED WITHIN (10) DAYS		
					Certified Tester In	formatio	n – Ple	ase Prin					
CERTIFY T	THAT ALL	INFORMATI	ON ON	THIS	REPORT IS TRU	E AND	ACCUR	RATE.					
Fester's Name	(PRINTED)	:							_Cert				
Test Equipment: Make:			_ModelSN#Cal. Date										
Tester's CO. Name:			PH#:										
Tester's Signature:						,	Date:						